

4th

International Seminar on ORC POWER SYSTEMS

ORC²⁰₁₇
13 - 15 September
MILANO, Italy

FCT
Fundação para a Ciência e a Tecnologia
MINISTÉRIO DA CIÊNCIA, TECNOLOGIA E ENSINO SUPERIOR

 **Laeta**
laboratório associado



• U  C •

FCTUC FACULDADE DE CIÊNCIAS
E TECNOLOGIA
UNIVERSIDADE DE COIMBRA

 **DEM**
Departamento de Engenharia Mecânica

DEVELOPMENT OF A DIRECT CONCEPT HELICAL-COIL EVAPORATOR FOR AN ORC BASED MICRO-CHP SYSTEM

João S. Pereira ^{a*}, José B. Ribeiro ^a, Ricardo Mendes ^a, Gilberto C. Vaz ^{a,b}, Jorge C. André ^a.

* PhD student in Sustainable Energy System at MIT Portugal Program in University of Coimbra.

^a ADAI-LAETA, Department of Mechanical Engineering, University of Coimbra, Pólo II, 3030 Coimbra, Portugal.

^b Instituto Politécnico de Coimbra – Instituto Superior de Engenharia de Coimbra, 3030 Coimbra, Portugal.



MIT Portugal 

Massachusetts Institute of Technology

15 of September of 2017


MOTIVATION

Reference: World Energy Council, *World Energy Resources - 2013 Survey*, 2013

	1993	2011	2020	% growth (1993-2011)
Population [billion]	5.5	7	8.1	27%
Gross domestic product [trillion USD]	25	70	65	180%
Total primary energy demand [Mtoe*]	9 532	14 092	17 208	48%
Coal [Mt*]	4 474	7 520	10 108	68%
Oil [Mt*]	3 179	3 973	4 594	25%
Natural gas [bcm*]	2 176	3 518	4 049	62%
Nuclear [TWh*]	2 106	2 386	3 761	13%
Hydro power [TWh*]	2 286	2 767	3 826	21%
Biomass [Mtoe*]	1 036	1 277	1 323	23%
Other renewables [TWh*]	44	515	1 999	1170%
Electricity production/year				
Total [TWh*]	12 607	22 202	23 000	76%
Per capita [MWh*]	2	3	3	52%
CO₂ emissions/year				
Total CO ₂ [Gt*]	21	30	42	44%
Per capita [tonne CO ₂]	4	4	n/a	11%




* **Mtoe** Million tonnes of oil equivalent; **Mt** Mega tonne; **Gt** Giga tonne; **bcm** Billion of cubic meters;
TWh Tera Watt hour; **MWh** Mega Watt hour;

Total Primary Energy Supply by resource





HEBE PROJECT

COMBINATION
BOILER SYSTEM



HEBE POTENTIAL IN THE EU-27





Reference: CODE 2 - Cogeneration Observatory and Dissemination Europe. Micro-CHP potential analysis - European level report. 2014

	Residential systems ($\pm 1 \text{ kW}_e$)*	SME and Collective systems ($\pm 40 \text{ kW}_e$)**
Expected sales:	in 2020: 52 000 units/year; in 2030: 2 900 000 units/year;	Expected sales: in 2020: 2 700 units/year; in 2030: 68 000 units/year;
Expected stock:	in 2020: 103 000 units; in 2030: 14 400 000 units; in 2040: 30 500 000 units;	Expected stock: in 2020: 18 000 units; in 2030: 290 000 units; in 2040: 950 000 units;
Potential primary energy savings in 2030:		
	300 000 TJ*** /year;	240 000 TJ*** /year;
Potential GHG-emissions reduction in 2030:		
	13 MtCO _{2,eq} *** /year;	14 MtCO _{2,eq} *** /year;

* by replacement technology; ** by add-on technology; *** TJ Tera Joule; MtCO_{2,eq} Mega tonne of CO₂ equivalent;

HEBE SPONSORS


sciven



FEDER Funds through the program COMPETE: QREN-POFC-COMPETE-23101



SYSTEM TARGET



DIRECT EVAPORATOR DESIGN FEATURES

Size


Efficiency

Power modulation capacity

Safe & reliable

EVAPORATOR PROTOTYPE

WORKING PRINCIPLE



DIRECT EVAPORATOR DESIGN FEATURES

Size

Efficiency

Power modulation capacity

Safe & reliable

EVAPORATOR PROTOTYPE

MODELING

Micro-CHP Hebe	Comercial limitations	Combustion model
Working fluid selection	Tube dimensions (D_e, D_i) and properties (k_t)	Composition of the combustion gases
Working fluid temperatures ($T_{f,in}, T_{f,out}$)	Burner nominal power (\dot{Q}_c)	Combustion gases temperatures ($T_{g,in}, T_{g,out}$)
Working fluid mass flow rate (\dot{m}_f)	Burner dimensions	Combustion gases mass flow rate (\dot{m}_g)
Required power (\dot{Q}_f)		


$$A_{ht}(L_t, D_e) = (NTU, U_{ht}, C_{min})$$

$$\longrightarrow NTU \left(\frac{C_{min}}{C_{max}}, \varepsilon \right), \text{ where } \varepsilon (\dot{Q}_f, \dot{Q}_c)$$

$$\longrightarrow U_{ht} (h_h, R_w(k_t), h_c), \text{ where } h_x (Re_x, Nussel_x, k(T_x, p_x), D_x)$$

$$\longrightarrow C_{min/max} (cp(T_x, p_x), \dot{m}_x)$$

Final output: $L_t \cong 19,4 [m]$ given $\cong 24$ coils



EVAPORATOR PROTOTYPE


CONSTRUCTION & ASSEMBLY

Model	▼ RX 35 S/PV	▼ RX 70 S/PV	▼ RX 110 S/PV	
Burner operation mode	Modulating (with variable speed)			
Modulation ratio at max. output	7 ÷ 1	8 ÷ 1	8 ÷ 1	
Servo-motor	type	--		
	run time s	--		
Heat output	kW	5 - 35	9 - 70	14 - 110
	Mcal/h	4,3 - 30,1	7,7 - 60,2	12 - 94,6
Working temperature	°C min./max. 0/40			



EVAPORATOR PROTOTYPE

PRELIMINARY TESTS




During the preliminary tests...




EVAPORATOR PROTOTYPE

ACCIDENT DIAGNOSTIC



**Examples of dangerous operational situations
(Burner manufacturer contact)**





Burner operating in open chamber mode (emissivity = 0.7)

Burner operation without surrounding (emissivity = 0.9):
 Left picture: nominal power of 30% (Sp1 = 789.1 °C and Sp2 = 958.1 °C);
 Middle picture: nominal power of 50% regular picture (Sp1 = 827.2 °C and Sp2 = 1006 °C);
 Right picture: nominal power of 50% thermal picture (Sp1 = 267.8 °C and Sp2 = 1025.2 °C).
 Right picture: nominal power of 70% thermal picture (Sp1 = 861.2 °C and Sp2 = 1025.2 °C).


EVAPORATOR PROTOTYPE

REDESIGNED WORKING PRINCIPLE AND SAFETY OPERATIONAL TESTS



EVAPORATOR PROTOTYPE

THERMAL CHARACTERIZATION: TEST BENCH



Measured parameters	Sensor-type	Operation limits	Uncertainty
Working fluid and water flow rate	Vane turbine flowmeter (infra-red sensor)	max. 20 bar; max. 25 L/min; max. 70 °C	+/- 2%
Water and natural gas temperature	RTD PT100	-50 to 500 °C	B class
Working fluid, flue gases and air temperature	Thermocouple type 'K'	-40 to 1100 °C	+/- 0.75%
Air humidity	External capacitive sensor	0 to 100%	+/- 2,5%
Working fluid pressure	Relative pressure transducers	0 to 25 bar; -40 to 149 °C	0.25% FS
Natural gas flow rate	Diaphragm gas meter	0 to 1,5 bar; -25 to 55°C	Class 1.5 - by EN 1359
Combustion products	Dry flue gas analyser with non-dispersive infrared sensor for O ₂ , CO ₂ , CO	O ₂ : 0 to 25%; CO ₂ : 0 to 20%; CO: 0 to 10%	O ₂ : 0.01%; CO ₂ : 0.02%; CO: 0.1%

EVAPORATOR PROTOTYPE

THERMAL CHARACTERIZATION: METHODOLOGY

Stage 1: With water as working fluid (in a open circuit):

- Burner capacity: 10%, 20%, 40%, 50%, 70%, 90% and 100%;
- Working fluid mass flow rate: 0,1 kg/s, 0,15 kg/s and 0,2 kg/s;
- Water (CW) mass flow rate: 0,1 kg/s;
- Time: 300 seconds.

Stage 2: With R245fa (HEBE micro-CHP system integrated):

- Burner capacity: 17%, 22%, 25% and 30%;
- Working fluid mass flow rate: adjusted on-site (P1 rotation);
- Water mass flow rate: 0,1 kg/s;
- Time: 300 seconds.

Variable objective [unit]

Mathematical equation

Combustion power [kW]

$$\dot{Q}_{comb} = \sum_P(\dot{n} \times \bar{h}_f^o)_P - \sum_R(\dot{n} \times \bar{h}_f^o)_R$$

Pre-heating water power [kW]

$$\dot{Q}_w = \dot{m}_w \times c_{p_w} \times \Delta T_w$$

Working fluid power [kW]

$$\dot{Q}_f = \dot{m}_f \times \Delta h_f$$

Flue losses [kW]

$$\dot{Q}_{flue} = \sum(\dot{n}_p \times \Delta \bar{h}_p)$$

Other losses [kW]


$$\dot{Q}_{loss} = \dot{Q}_{comb} - \dot{Q}_w - \dot{Q}_f - \dot{Q}_{flue}$$

Global efficiency [%]

$$\eta_{global} = (\dot{Q}_f + \dot{Q}_w) / \dot{Q}_{comb}$$


EVAPORATOR PROTOTYPE

THERMAL CHARACTERIZATION: RESULTS




EVAPORATOR PROTOTYPE

THERMAL CHARACTERIZATION: RESULTS




Burner capacity [%]	10	20	40	50	70	90	100
Combustion power [kW]	9.053	11.532	20.598	24.952	31.557	35.855	37.053
Water power [kW]	3.064	3.383	4.473	4.524	4.967	5.224	5.016
Working fluid power [kW]	5.134	6.594	12.063	15.61	20.06	23.345	24.565
Flue losses [kW]	0.412	0.447	1.248	1.923	3.106	3.864	4.206
Other losses [kW]	0.443	1.108	2.814	2.895	3.424	3.422	3.266
Global efficiency [%]	90.6	86.52	80.28	80.69	79.31	79.68	79.83



Burner capacity [%]	17	22	25	30
Combustion power [kW]	10.907	12.445	13.928	16.047
Water power [kW]	3.218	3.538	3.747	3.974
Working fluid power [kW]	4.695	5.864	6.213	7.275
Flue losses [kW]	0.646	1.001	1.28	1.756
Other losses [kW]	2.348	2.266	2.688	3.042
Global efficiency [%]	72.55	75.55	71.51	70.1

EVAPORATOR PROTOTYPE

CONCLUSIONS & FUTURE WORK



- A burner heat-exchanger set was built to perform the direct vaporization of the organic fluid of an ORC system.
- Fulfill safety and control requests;
- The heating transfer coefficient of the external flow needs to be optimized;
- The external chamber appears to have very potential:
 - i. Preclude the overheating of the gas-burner head;
 - ii. Increasing the ORC efficiency by pre/post heating the end user water;
 - iii. Decreasing the combustion gas temperature before reaching the organic fluid, reducing the risk of thermal degradation;

THANK YOU FOR
YOUR ATTENTION



João Silva Pereira

(joao.pereira@dem.uc.pt)